



Panos Konstantin

Power and Energy Systems Technologies & Economics

Case Study Integrated Model Cost Allocation _Electrical Equivalent Extraction-Condensing CHP

Notes:

1. Cells with black characters include inputs
2. Cells with red characters include formulas

Last update March. 2016



Panos Konstantin

Disclaimer

The Examples are solely and exclusively indented to provide support and assistance to the readers for practicing and better understanding of the theoretical part of this book.

.

The author, Panos Konstantin, believes that all information and guidance provided and all calculations in these examples are correct. Nevertheless anyone using these examples should carry out their own due diligence and appraisal of the contents.

No warranty is made nor responsibility or liability is taken or accepted by the author for adequacy, completeness or accuracy of the examples or assumptions on which they are based.

.

The author does not assume any liability to anyone for any loss or damage caused by any error or omission in this work, regardless of whether such error or omission is the result of negligence or any other reason. Any and all such liability is completely disclaimed.

Panos Konstantin owns all intellectual property rights and all copyright shown in this website, unless otherwise stated.

Proposals for improvements of the contents are welcome and will be considered in upcoming updates!

Last Update March 2016

TE-CaseStudy-9_Cost-Allocation_Elect-Equivalent-Extraction-cond-CHP.xls
Performance

Performance Calculations

Item		Formulas	Unit	Values
Extraction-condensing cycle, rated output				
Rated electrical output, gross		P_{gross}	MW _e	110.0
Rated electrical output, net	9 kW	P_{net}		101.0
Heat extraction at 12 bar	100 t / h	Q_{12bar}	MW _t	70.7
Heat extraction at 6 bar	50 t / h	Q_{6bar}	MW _t	33.7
Firing power rate		Q_f	MW _t	359.7

Performance parameters				
Tota efficiency, cogeneration		η_{tot}	-	82.5%
Electricity-to-heat ratio, 12 bar steam		σ_{12bar}	kWh _e / kWh _t	0.335
Electrical equivalent, 12 bar steam		$\beta_{12 bar}$	kWh _e / kWh _t	0.289
Electricity-to-heat ratio, 6 bar steam		σ_{6bar}	kWh _e / kWh _t	0.403
Electrical equivalent, 6 bar steam		$\beta_{6 bar}$	kWh _e / kWh _t	0.255

Annual Energy Balance				
Electricity generation, gross, total	7,500 h/a	W_{gross}	MWh _e / a	825,157
of which cogenerated		$W_{cogen} = \sum \sigma_i \times Q_i$	MWh _e / a	215,011
Electricity generation, net, total	7,500 h/a	W_{net}	MWh _e / a	757,657
Heat generation 12 bar	6,500 h/a	$Q_{t, 12 bar}$	MWh _t / a	459,720
Heat generation 6 bar	4,500 h/a	$Q_{t,6 bar}$	MWh _t / a	151,530
Fuel consumption		Q_f	MWh _t / a	2,579,642

Equivalent cond. cycle performance				
Cond. Equivalent power, gross		P_{cond_equ}	MW _e	139.1
Cond. equivalent elect. Efficiency		η_{cond_equ}	-	38.66%

Cond. equivalent annual electricity production				
Annual electricity production, gross	7,500 h/a	$W_{e_net} = P_{net} \times t_{FLH}$	MWh / a	825,157
Equivalent elec. production, 12 bar steam	459,720	$\beta_{12 bar} \times Q_{t, 12 bar}$	MWh / a	132,908
Equivalent elec. production, 6 bar steam	151,530	$\beta_{6 bar} \times Q_{t, 6 bar}$	MWh / a	38,621
Fuel consumption		Q_f	MWh _t / a	2,578,078

Deviation 0.06%

TE-CaseStudy-9_Cost-Allocation_Elect-Equivalent-Extraction-cond-CHP.xls
Electricity gen. costs

Electricity generation cost

Item			Unit	Value
Power and energy balance, cond. Equivalent				
Power output, gross			MW _e	139.1
Power output, net	9.0	<i>P_{net}</i>	MW _e	130.1
Electricity generation, gross	7,500 h/a		GWh _e /a	1,042.9
Electricity generation, net	7,500 h/a	<i>W_{net}</i>	GWh _e /a	975.4
Fuel consumption			GWh _f /a	2,578.1
Financial parameters				
Discount rate, in real terms			-	6.5%
Lifetime			a	30.0
Fuel price	85 €/tce	8.14 €/tce	€/ MWh _t	10.4
CAPEX	2001 €/kW		mIn €	278.2
Annual generation costs, in real terms				
Annualized CAPEX	<i>CT</i>		mIn € /a	59.5
OPEX fixed	3.5% x CAPEX	<i>CC</i>	mIn € /a	21.3
Fuel cost	<i>COF</i>		mIn € /a	9.7
Non-fuel variable costs	1.50 €/MWh _e	<i>CF</i>	mIn € /a	26.9
		<i>CV</i>	mIn € /a	1.6
Specific electricity generation cost, in real terms				
Composite generation cost	$ce=CT/P_{e_net}$		€/ MWh _e	61.03
Capacity cost	$cc_e=(CC+COF)/W_{e_net}$		€/ kW a	238.68
Energy cost	$cv_e=(CF+CV)/W_{e_net}$		€/ MWh _e	29.20

input CAPEX

TE-CaseStudy-9_Cost-Allocation_Elect-Equivalent-Extraction-cond-CHP.xls
 Cost Allocation

Cost Allacation


Item		Formulas	Unit	Value
Electricity generation cost				
Composite cost	$t_{FCH}=7,500 \text{ h/a}$	$ce=1000*cc_e/t_{FCH}+cv_e$	€ / MWh	61.03
Capacity cost		cc_e	€ / (kW _a)	238.68
Energy cost		cv_e	€ / MWh	29.20
Heat generation cost, 12 bar steam				
Composite cost	$t_{FCH}=6,500 \text{ h/a}$	$c_{H12}=1000*cc_{12}/t_{FCH}+c_{v12}$	€ / MWh	19.06
Capacity cost	$\beta=0.289$	$cc_{12}=\beta_{12bar} \times cc_e$	€ / (kW _a)	69.00
Energy cost		$cv_{12}=\beta_{12bar} \times cv_e$	€ / MWh	8.44
Heat generation cost, 6 bar steam				
Composite cost	$t_{FCH}=4,500 \text{ h/a}$	$c_{H6}=1000*cc_6/t_{FCH}+cv_6$	€ / MWh	20.96
Capacity cost	$\beta=0.255$	$cc_6=\beta_{6bar} \times cc_e$	€ / (kW _a)	60.83
Energy cost		$cv_6=\beta_{6bar} \times cv_e$	€ / MWh	7.44

TE-CaseStudy-9_Cost-Allocation_Elect-Equivalent-Extraction-cond-CHP.xls
Control Results

Control Calculation

Item	Output	Spec. Cost	Unit	Value
Electricity			th. € /a	55,316
Capacity	139.1	238.68	th. € /a	33,189
Energy	757,657	29.20	th. € /a	22,127
12 bar steam			th. € /a	8,762
Capacity	70.7	69.00	th. € /a	4,880
Energy	459,720	8.44	th. € /a	3,881
6 bar steam			th. € /a	3,176
Capacity	33.7	60.83	th. € /a	2,048
Energy	151,530	7.44	th. € /a	1,128
Total	-	-	th. € /a	67,254
Electricity	757,657	61.03	th. € /a	46,239
12 bar steam	459,720	19.06	th. € /a	8,762
6 bar steam	151,530	20.96	th. € /a	3,176
Total	-	-		58,177

TE-CaseStudy-9_Cost-Allocation_Elect-Equivalent-Extraction-cond-CHP.xls
 CHP-no reheat



Generator power, gross	MW	110.0
Firing power rate:	MW	359.7
Live steam	MW	359.7
Reheat	MW	0
Electrical efficiency, gross	%	30.59%
Total efficiency	%	59.61%